

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20177**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-1, Boys' Rm - next to 103 Left

Collect Date: 09/28/2016
Collect Time: 06:04
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20178**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-2, Boys' Rm - next to 103 Right

Collect Date: 09/28/2016
Collect Time: 06:04
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20179
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-3, Girls' Rm - across office

Collect Date: 09/28/2016
Collect Time: 06:08
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20180**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-4, Girls' Rm - across office

Collect Date: 09/28/2016
Collect Time: 06:08
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20181**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-5, Girls' Rm - across office

Collect Date: 09/28/2016
Collect Time: 06:08
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20182**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-6, Band Rm 140

Collect Date: 09/28/2016
Collect Time: 06:12
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20183**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-7, Women's next to 1:26 L

Collect Date: 09/28/2016
Collect Time: 06:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20184**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-8, Women's next to 1:26 M

Collect Date: 09/28/2016
Collect Time: 06:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20185**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-9, Women's next to 1:26 R

Collect Date: 09/28/2016
Collect Time: 06:15
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20186
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-10, Boys by stair 16 - Left

Collect Date: 09/28/2016
Collect Time: 06:19
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20187**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-11, Boys by stair 16 - Right

Collect Date: 09/28/2016
Collect Time: 06:19
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20188**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-12, Girls by stair 16 - Right

Collect Date: 09/28/2016
Collect Time: 06:20
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20189**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-BF-13, Girls by stair 16 - Left

Collect Date: 09/28/2016
Collect Time: 06:20
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20190
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-KC-14, Kitchen hand wash

Collect Date: 09/28/2016
Collect Time: 06:23
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20191**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-15, Rm 161 - Custodial sink

Collect Date: 09/28/2016
Collect Time: 06:27
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20192
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-16, Art Rm 160 - Right of door

Collect Date: 09/28/2016
Collect Time: 06:29
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.013, 0.015, mg/L, SM3113B, MN, 11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

**573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061**

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20193
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-17, Art Rm 160 - Left

Collect Date: 09/28/2016
Collect Time: 06:29
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
P	Sample preserved at lab	Z	Analysis is not state-certified	C	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits		
(+ Result may be biased high / - Result may be biased low)					

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20194**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-18, Art Rm 167 - Right

Collect Date: 09/28/2016
Collect Time: 06:30
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- P Sample preserved at lab
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
 Environmental Laboratory Supervisor and contact person
 If you have questions, please call.
 (518) 525-5480 / 5479

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1

Sample ID: AW20195
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-CF-19, Art Rm 167 - Left

Collect Date: 09/28/2016
Collect Time: 06:30
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, <0.001, 0.015, mg/L, SM3113B, MN, 11/15/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
P Sample preserved at lab
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
Z Analysis is not state-certified
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank
C Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20196**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-EC-20, Art Rm 171 - Left of stove

Collect Date: 09/28/2016
Collect Time: 06:32
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved at lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 11/17/2016 Page 1 of 1
Sample ID: **AW20197**
Date Received: 09/29/2016
Time Received: 11:27
Date Finalized: 11/17/2016
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Hudson
Sample Loc: 102 Harry Howard Ave., Hudson
Sample Pt: MC-1-EC-21, RM 171 - Right of stove

Collect Date: 09/28/2016
Collect Time: 06:32
Collected by: D. BAUER & S. NAGEL
Receipt Temp: 21 C See Note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/15/2016

Qualifiers Key:

- | | | |
|--|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| P Sample preserved at lab | Z Analysis is not state-certified | C Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | |
| (+ Result may be biased high / - Result may be biased low) | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.